



**FRAME FOR DOUBLE LID**  
(Flygt 3127 & 3153 Pumps)

**DOUBLE LID**  
(Flygt 3127 & 3153 Pumps)

**NOTES:**

1. All dimensions in mm.
2. All welds to be continuous.
3. Frames to be 316 Stainless Steel.
4. Lids to be 6mm aluminium checker plate.
5. Lids and frames to be matched set.
6. Grouting lugs to be welded to frame 100mm in from each corner as shown in plan view - Refer to Drawing 'WASTEWATER PUMP STATION LID FRAME DETAIL'.
7. Lid and frame for low head pumps will require specific design.
8. Dimensions A and B to suit upper section - Refer to Drawing 'WASTEWATER PUMP STATION UPPER SECTION REINFORCING'.