



MANIFOLD ASSEMBLY FOR MULTIPLE WATER CONNECTIONS

NOTES:

1. In-line or one-sided arrangements permitted to suit site conditions.
2. Connections from rider mains to be made using 63 x 63 MDPE tee in place of a tapping band or tapped gibault. Tee to be placed horizontally to maintain standard cover.
3. Manifolds with pressure caps to be installed on all DN20 domestic connections. Meters installed on all connections serving commercial, industrial zoned lots and residential where required by Council.

NOT TO SCALE