



NOTES:

1. Upstream and downstream spacing in accordance with manufacturer's specification or otherwise minimum 5 times pipe diameter.
2. Isolation washers and gaskets to be used between components of dissimilar metals.
3. Meter box sized to contain all fittings.
4. In new installations tapping band may be replaced by cut-in tee, tapped gibault or other as directed.
5. Any backflow requirements necessary to comply with the NZ Building Code G12 shall be installed within the Lot, to be owned and maintained by the property owner.

NOT TO SCALE